

FEC has the authority of interpretation of "neat and workman-like manner" based on our experiences or precedents as the basis of our judgements.

1. Members are responsible for rack, panels, ground rod, gutter and conduit, along with wire from panel to tails at weather head.
2. Wiring, installation, and materials must conform to the requirements of the NEC, TDLR, and NESC.

First Standoff to
be 2' above
ground level

8' Ft Tails

1. Members are responsible for rack, panels, ground rod, gutter and conduit, along with wire from panel to tails at weather head.
2. Wiring, installation, and materials must conform to the requirements of the NEC, TDLR, and NESC.

Must be filled

- Legs to be encased in concrete



FEC
FAYETTE ELECTRIC COOPERATIVE, INC.
Your Touchstone Energy® Cooperative

-10-